



Office of the District Fire Officer
Karnataka State Fire & Emergency Services
VIJAYAPUR Fire Station , VIJAYAPUR-586101
Telephone:08352-270160



C.NO.185/FSCR/DFO/VIJAYAPUR/2026

Date-17/04/2026

To,
The Principal
Shri Basaveshwar Temple International School
Basavan Bagewadi,
Tq -Basavan Bagewadi,District-Vijayapur.

Sub:Issue of "Fire Safety Compliance Report" to "Shri Basaveshwar Temple International School", Located At Sy. No-1308/*/1 to 8A-6-G-22, Basavan Bagewadi City, Tq-Basavan Bagewadi, District-Vijayapur.

- Ref:1. NO:GBC(2)2100/2025 Date:03/02/2026
2. Applicants Request Letter Date -03/03/2026
3. C NO-98/ADV/CFO/HBL/2021 Date:20/07/2021
4. C.No.03/FSCR/FSO/B.BGD/2026 Date:27/03/2026

×××××*@*×××××

With reference to the subject above cited, the premises of "Shri Basaveshwar Temple International School", Located At Sy. No-1308/*/1 to 8A-6-G-22, Basavan Bagewadi City, Tq-Basavan Bagewadi, District-Vijayapur. was inspected by The Fire Station Officer, Basavan Bagewadi on 27/03/2026 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height)

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the building / premises :-

01.	Name and Address of the Applicant.	:	The Principal Shri Basaveshwar Temple International School Basavan Bagewadi, Tq-Basavan Bagewadi, District-Vijayapur
02.	Name and Address of the premises.	:	Shri Basaveshwar Temple International School, Located At Sy. No-1308/*/1 to 8A-6-G-22, Basavan Bagewadi City, Tq-Basavan Bagewadi, District-Vijayapur
03.	Name and address of the Building owner	:	The Principal Shri Basaveshwar Temple International School Basavan Bagewadi, Tq-Basavan Bagewadi, District-Vijayapur
04.	Number of buildings	:	01 Building
05.	Number of floors	:	Ground+01 upper floor
06.	Details of occupancy:-	:	Class Room's-10no's, Office Room-02, Library-01.




17/04/26

	1 st Floor	:	Class Room's-10no's, Office Room-02, Library-01.
07.	Height of the building	:	09.20 Mtrs.
08.	Site area	:	2428.99 Sq Mtr
09.	Built-up area of each floor:-		
	Ground Floor	:	1285.00 Sq Mtr
	1 st Floor	:	1285.00 Sq Mtr
10.	Total built-up area	:	2570.00 Sq Mtr
11.	Surrounding properties:-		
	East	:	Play Ground
	West	:	Temple
	North	:	Agriculture Land
	South	:	Approach Road
12.	Set-back area available around the building :-		
	East	:	03.00 mtr
	West	:	03.00 mtr Play Ground
	North	:	20.00 mtr
	South	:	02.00 mtr
13.	School Dis Code		29030323501

B. On inspection of this Institutional premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premise is abutting by 09.00 mtrs. Wide hard surfaced road located on Southern side.	Adequate
02	No. of entrances	Provided 02 no of entrance Sothern side & no of Exit Eastern Side	-
03.	Width of entry / exit	Each 06.00 mtr Width of entry & Exit	-
04.	No. of staircases available	Nos. of staircases	The staircase must be free from Obstruction all the time.
		Width of staircases	
		Width of treads	
		Height of risers	
		Nos. of riser per flight	
		Height of handrails	
		Provided 12 no's of ABC Type Fire extinguishers Each 06.00 Kgs Capacity, & 01 no's of CO2 Type Fire eextinguishers Each 4.5 Kgs Capacity.	
			Complied



19/04/26

06.	Escape routes	Escape route has been marked with luminous light/paint at ground and 1 st floor. The Students and Employees directing towards exists and emergency exists.	Complied
07.	Fire order	A notice board indicating the action to be taken by the employees in case of any emergency has been displayed with the telephone numbers of Basavan Bagewadi Fire Station 083358-244101, 112 & 101, and the telephone nos nearest ambulance services and police station.	Complied
08.	No Smoking board	COPTA Sec-4, smoking here is an offence board has been written & displayed in English & Kannada both languages.	Complied
09.	Fire Siren	A Fire Siren has been installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.	Complied
10.	Nominate One Fire Nodal Officer	Shri Vijayakumar Rathod has been nominated as the Fire nodal officer.	Complied
11.	Fire fighting training	At least 40% of employees shall be trained in basic fire fighting course at our R.A.Mundkur Fire and Emergency Services Training Academy, Bannerghatta Road, Bangalore-29, or Regional training centre hubballi or District Fire Station Vijayapur. No Trained Persons	
12.	<u>Fire Precautionary Measures</u> <i>Flammable and combustible materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.</i> <i>Accumulation of combustible waste in and around the premises should be avoided.</i> <i>Exit ways shall be always kept clear without any obstruction.</i> <i>Flammable petroleum gas should not be stored in the building.</i> <i>The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</i> <i>During the class hours the class room door shall not be locked from inside to out side.</i> <i>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.</i>		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "**Fire Safety Compliance Report**" to "Shri Basaveshwar Temple International School", Located At Sy. No-1308/*/1 to 8A-6-G-22, Basavan Bagewadi City, Tq-Basavan Bagewadi, District-Vijayapur.

This "**Fire Safety Compliance Report**" is valid for only one year from the date of issue.

Yours Faithfully

Bijub
18/04/26

DISTRICT FIRE OFFICER
VIJAYAPUR-586108

FIRE SAFETY CERTIFICATE

C.NO:185/FSCR/DFO/VIJAYAPUR/2026

Date : 17/04/2026

Certified that the "Shri Basaveshwar Temple International School, located at Sy.No 1308/*1 to 8A-6-G-22, Basavan Bagewadi City, Tq-Basavan Bagewadi, District-Vijayapur. Comprised of **Zero Basement, Ground & 1 Upper Floors** Owned/Occupied by Shri Basaveshwar Temple International School, Basavan Bagewadi City have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the **Fire Station Officer, Basavan Bagewadi on 27/03/2026** in the presence of The Head Master, **Smt. Rohini M Ronad**, and that the Building/Premises is fit for occupancy upto classes Xth with effect from **17/04/2026 for a period of One Year** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Maintenance of all fire fighting installations periodically
- 2.
- 3.
- 4.

Issued on 17/04/2026 at Vijayapur, by



Signature with Seal : S.S.Nilgar

Signature with Seal : S.S.Nilgar

Designation : District Fire Officer

Name & Address : District Fire Officer

of Department/Office : Office of the District Fire Officer
Karnataka State Fire & Emergency
Services, Takke Road , Vijayapur-
586102

To,

The Principal

Shri Basaveshwar Temple International School
Basavan Bagewadi,

Tq -Basavan Bagewadi,District-Vijayapur **ENDORSEMENT**

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(Name and Designation of the authorized signatory)

The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with original vernacular certificate as a single pdf.



ಚಲನ್ ಚಾಲ್ತಿ ಅವಧಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ಡಿಡಿ ಕಛೇರಿ DDO Office
7 Days	VIJAYAPURA	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DISTRICT FIRE OFFICE, BILAPUR
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ Challan Reference Number	ಡಿಡಿ ಕೋಡ್ DDO Code
Government	17/04/2026 14:47:03	CR0426007000639290	140120
ಸಂದಾಯದಾರನ ಹೆಸರು Remitter Name		THE PRINCIPAL SHRIBASAVESHWAR TEMPLE INTERNATIONAL SCHOOL BASAVANBAGEWADI	ಮೊಬೈಲ್ ಸಂಖ್ಯೆ Mobile Number
			9481573052
ವಿಳಾಸ Address	SHRI BASAVESHWAR TEMPLE INTERNATIONAL SCHOOL BASAVAN BAGEWADI CITY TQ BASAVAN BAGEWADI DIST VIJAYAPUR		
ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID
COLLECTION OF FEES AND OTHER RECEIPTS FROM FIRE DEPARTMENT	0070-60-109-0-02-000	CLEARANCE CERTIFICATE	Docket No. : CNO 185/FSCR/DFO/VIJAYAPUR/2026 DATE 17/04/2026
ಸಂದಾಯ ಮಾಡುವ ಬ್ಯಾಂಕ್ Remittance Bank	State Bank of India e Pay	ಒಟ್ಟು ಮೊತ್ತ Grand Total	22000.00
		ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words	Twenty Two Thousand Only
ಪಾವತಿ ವಿವರಗಳು(Payment Details)			
ಪಾವತಿ ವಿಧ Payment Mode		Netbanking	

*ನಿಮ್ಮ ವಹಿವಾಟನ್ನು ಸಂಸ್ಕರಿಸಲಾಗಿದೆ. ಮುಂದಿನ ಉಲ್ಲೇಖಕ್ಕಾಗಿ ದಯವಿಟ್ಟು ವಹಿವಾಟಿನ ಸಂಖ್ಯೆಯನ್ನು ಬರೆದಿಟ್ಟುಕೊಳ್ಳಿ. ವಹಿವಾಟು ಸಂಖ್ಯೆ.

Your Transaction has been processed. Please note the Transaction number for future reference. Transaction No. 5870460954445

*ಶ್ರೇಷ್ಠ ಕಾರ್ಡ್/ಡೆಬಿಟ್ ಕಾರ್ಡ್ ಮೂಲಕ ಮಾಡಿರುವ ಎಲ್ಲಾ ಪಾವತಿಗಳ ಮೇಲೆ ಹೆಚ್ಚುವರಿ ಸೇವಾ ಶುಲ್ಕ ಅನ್ವಯವಾಗುತ್ತದೆ. ಹಾಗೂ ಬ್ಯಾಂಕ್ ಅದನ್ನು ನೇರವಾಗಿ ಖರ್ಚು ಹಾಕುತ್ತದೆ.

Additional Service charges are applicable for all payments made through CC/DC and the same would be debited directly by the bank.
*ಯಾವುದೇ ಸಂದರ್ಭದಲ್ಲಿ ಸಂದಾಯದಾರನು ಶುಲ್ಕ ಮರುಪಾವತಿಯನ್ನು ಕೊರಬಾರದು

Under no circumstances the remitter will seek a Charge Back